



Notes:

1. Refer to City of Sanford drawing SD-R-003 for asphalt patch details if necessary.
2. Blow-Off assembly shall not be located in street pavement.
3. A saddle will be allowed in lieu of tapping a mechanical joint plug.



Two Inch Blow-Off Assembly

City of Sanford Engineering Dept - P.O. Box 3729 - Sanford, NC 27331

Dwg. No. SD-W-008

Date: 02/11/2020

Scale: Not To Scale

Drawn By: Staff