



Notes:

1. All assemblies shall be installed in compliance with all applicable City of Sanford ordinances and State of NC codes.
2. Contact the City of Sanford Utilities Connections Coordinator for additional information.
3. Double Check Valve Backflow Prevention Assembly shall comply with ASSE 1015 and AWWA C510.
4. Pad shall be minimum 4" thick concrete - 3000 psi @ 28 days or approved pre-fab equivalent.
5. Hotbox enclosures shall comply with ASSE 1060.
6. If provided, electrical outlets shall be GFCI.
7. Property owner shall be responsible for freeze protection, operation, maintenance, testing and reporting.



**Double Check Valve**  
**3/4" ~ 2" Backflow Prevention Assembly**  
 City of Sanford Engineering Dept - P.O. Box 3729 - Sanford, NC 27331

Dwg. No. SD-W-003
Date: 02/11/2020
Scale: Not To Scale
Drawn By: Staff