

ANNUAL
WATER
QUALITY
REPORT

Water testing performed in 2006

Proudly Presented By:
CITY OF SANFORD
WATER TREATMENT
PLANT



PWS ID#: 0353010

Este informe contiene información muy importante sobre su agua potable. Tradúzcalo o hable con alguien que lo entienda bien.

Source Water Assessment Program

The North Carolina Department of Environmental and Natural Resources (DENR), Public Water Supply (PWS) Section, Source Water Assessment Program (SWAP), conducted assessments for all drinking water sources across North Carolina. The purpose of the assessments was to determine the susceptibility of each drinking water source (well or surface-water intake) to potential contaminant sources (PCSs). The results of the assessment are available in SWAP reports, which include maps, background information, and a relative susceptibility rating of higher, moderate, or lower.

The relative susceptibility rating of the water source for the City of Sanford was determined by combining the contaminant rating (i.e., the number and location of PCSs within the assessment area) and the inherent vulnerability rating (i.e., the characteristics or existing conditions of the watershed and its delineated assessment area). The assessment found that the Cape Fear River has a higher susceptibility rating. It is important to note that a susceptibility rating of "higher" does not imply poor water quality but rather the system's potential to become contaminated by PCSs in the assessment area.

The complete SWAP report for the City of Sanford may be viewed on the Internet at www.deh.enr.state.nc.us/pws/swap. To obtain a copy of this report, please mail a written request to Water Assessment Program - Report Request, 1634 Mail Service Center, Raleigh NC 27699-1634, or email a request to swap@ncmail.net. Please indicate the name and identification number of your public water supply system, as well as your name, mailing address and phone number. If you have any questions about the SWAP report, please contact the Source Water Assessment staff by phone at (919) 715-2633.

Continuing Our Commitment

Once again, we proudly present our annual water quality report. This edition covers all testing completed from January 1 through December 31, 2006. We are pleased to inform you that our compliance with all state and federal drinking water laws remains exemplary. As in the past, we are committed to delivering the best quality drinking water. To that end, we remain vigilant in meeting the challenges of source water protection, water conservation, and community education while continuing to serve the needs of all of our water users.


For more information about this report or for any questions relating to your drinking water, please call Scott M. Christiansen, Water Treatment Plant Superintendent, at (919) 775-8307.

Community Participation

You are invited to participate in our public forum and voice your concerns about your drinking water. The City of Sanford Council meets the first and third Tuesday of each month beginning at 1 p.m. and 7 p.m. respectively at City Hall, 225 East Weatherspoon Street, Sanford, NC.

Important Health Information

Some people may be more vulnerable to contaminants in drinking water than the general population. Immunocompromised persons such as those with cancer undergoing chemotherapy, recipients of organ transplants, those with HIV/AIDS or other immune system disorders, the elderly, and infants may be at risk from infections. These people should seek advice from their health care providers about the drinking water. The U.S. EPA/CDC (Centers for Disease Control and Prevention) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline at (800) 426-4791.



Maintaining Water Quality

One of the top priorities for the City of Sanford is to maintain water quality throughout the distribution system. Water quality tends to deteriorate with time; therefore, we employ an aggressive flushing program to move water through the system so it does not remain in the distribution mains longer than necessary.

The City of Sanford recommends that businesses, churches, and schools that are routinely closed for long periods or that have extremely low water usage should flush their systems before use. Open all faucets and allow any water that may have become stagnant to be expressed. With your participation, we can maximize the quality of water reaching every customer.

Annual Switchover to Free Chlorine

After treatment and filtration, the City adds both chlorine and ammonia in carefully regulated doses for the final disinfectant. The addition of both chlorine and ammonia combine to form chloramines. The stability and effectiveness of chloramination make it an excellent form of disinfection. The North Carolina Department of Environment and Natural Resources requires that all systems using chloramines as a disinfectant stop adding ammonia and feed only chlorine for a one-month period annually to control any biological growth that may occur in the distribution system. During this one-month switch to chlorine, customers may notice a chlorine odor and some minor discoloration resulting from crews flushing the distribution system to hasten the change from chloramines to chlorine only. As with chloramines, chlorine needs to be removed from the water before its use in fish aquariums, kidney dialysis treatment, and certain light manufacturing activities.

Water Treatment Process

The treatment process consists of a series of steps. First, raw water is drawn from the Cape Fear River and is stored in a sixty-million-gallon reservoir. The water is gravity fed into a mixing tank, where a coagulant chemical is added. The addition of the coagulant chemical causes particles to adhere to one another (called floc), making them heavy enough to settle into a basin from which the sediment is removed. Chlorine is then added for disinfection. At this point, the water is filtered through multimedia filters composed of anthracite coal and silicate sand. As smaller, suspended particles are removed, the turbidity disappears and the clear water emerges.

Chlorine is added again as a safeguard against any bacteria that may be present as the water travels into a two-million-gallon storage tank. (We carefully monitor the amount of chlorine, adding the lowest quantity necessary to protect the safety of your water without compromising taste.) Finally, caustic soda (used to adjust the final pH and alkalinity), fluoride (used to prevent tooth decay), a corrosion inhibitor (used to protect distribution system pipes), and chlorine with ammonia (used to form chloramines for final disinfection) are added before the water is pumped to sanitized elevated storage tanks and into your home or business.

Where Does My Water Come From?

The City of Sanford's customers are fortunate because we enjoy an abundant water supply from a single surface-water source, the Cape Fear River. The Deep River, the Haw River, and the Rocky River form the headwaters of the Cape Fear River Basin. The City of Sanford Water Treatment Plant serves the City of Sanford, Lee County, the Town of Broadway, Carolina Trace, and parts of Chatham County. Our treatment facility provides roughly 2 billion gallons of clean drinking water every year.



Substances That Might Be in Drinking Water

To ensure that tap water is safe to drink, the U.S. EPA prescribes regulations limiting the amount of certain contaminants in water provided by public water systems. The U.S. Food and Drug Administration regulations establish limits for contaminants in bottled water, which must provide the same protection for public health. Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of these contaminants does not necessarily indicate that the water poses a health risk.

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals, in some cases, radioactive material and substances resulting from the presence of animals or from human activity. Substances that may be present in source water include:

Microbial contaminants such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, or wildlife;

Inorganic contaminants such as salts and metals which can be naturally occurring or may result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming;

Pesticides and herbicides which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses;

Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and which may also come from gas stations, urban stormwater runoff, and septic systems;

Radioactive contaminants, which can be naturally occurring or may be the result of oil and gas production and mining activities.

For more information about contaminants and potential health effects, call the U.S. EPA's Safe Drinking Water Hotline at (800) 426-4791.



Information on the Internet

Visit the City of Sanford's Web site (www.sanfordnc.net) for information on all city departments and departmental contacts. The U.S. EPA's Office of Water (www.epa.gov/watrhome) and the Centers for Disease Control and Prevention (www.cdc.gov) Web sites provide a substantial amount of information on many issues relating to water resources, water conservation, and public health. Also, the North Carolina Department of Environment and Natural Resources has a Web site (www.ehn.state.nc.us) that provides complete and current information on water issues in North Carolina, including valuable information about our watershed.



Sampling Results

During the past year, we have taken hundreds of water samples in order to determine the presence of any radioactive, biological, inorganic, volatile organic, or synthetic organic contaminants. The table below shows only those contaminants that were detected in the water. Although all of the substances listed here are under the Maximum Contaminant Level (MCL), we feel it is important that you know exactly what was detected and how much of the substance was present in the water. The state requires us to monitor for certain substances less than once per year because the concentrations of these substances do not change frequently. In these cases, the most recent sample data are included, along with the year in which the sample was taken.

REGULATED SUBSTANCES							
SUBSTANCE (UNIT OF MEASURE)	YEAR SAMPLED	MCL [MRDL]	MCLG [MRDLG]	AMOUNT DETECTED	RANGE LOW-HIGH	VIOLATION	TYPICAL SOURCE
2,4-D (ppb)	2006	70	70	0.39	NA	No	Runoff from herbicide used on row crops
Alpha Emitters (ppm)	2003	15	0	0.39	NA	No	Erosion of natural deposits
Beta/Photon Emitters ¹ (ppm)	2003	50	0	0.70	NA	No	Decay of natural and manmade deposits
Chloramines (ppm)	2006	[4]	[4]	3.0	0.6–4.4	No	Water additive used to control microbes
Chlorine (ppm)	2006	[4]	[4]	1.5	0.4–2.7	No	Water additive used to control microbes
Combined Radium (ppm)	2003	5	0	0.70	NA	No	Erosion of natural deposits
Fluoride (ppm)	2006	4	4	0.95	NA	No	Erosion of natural deposits; Water additive to promote strong teeth; Discharge from fertilizer and aluminum factories
Haloacetic Acids [HAA] (ppb)	2006	60	NA	31.56	21.08–54.25	No	By-product of drinking water disinfection
TTHMs [Total Trihalomethanes] (ppb)	2006	80	NA	65.69	33.75–123	No	By-product of drinking water chlorination
Total Coliform Bacteria (% positive samples)	2006	5% of monthly samples are positive	0	2	NA	No	Naturally present in the environment
Total Organic Carbon ² [TOC] - RAW (ppm)	2006	TT	NA	8.2	6.1–8.2	No	Naturally present in the environment
Total Organic Carbon ² [TOC] - TREATED (ppm)	2006	TT	NA	3.0	2.6–4.7	No	Naturally present in the environment
Turbidity (NTU) ³	2006	TT = 1 NTU	NA	0.19	0.03–0.19	No	Soil runoff
Turbidity (Lowest monthly percent of samples meeting limit)	2006	TT	NA	100	NA	No	Soil runoff

Tap water samples were collected from sample sites throughout the community

SUBSTANCE (UNIT OF MEASURE)	YEAR SAMPLED	ACTION LEVEL	MCLG	AMOUNT DETECTED (90 th percentile)	SITES ABOVE ACTION LEVEL	VIOLATION	TYPICAL SOURCE
Copper (ppm) ⁴	2005	1.3	1.3	0.103	0	No	Corrosion of household plumbing systems; Erosion of natural deposits; Leaching from wood preservatives

UNREGULATED SUBSTANCES

SUBSTANCE (UNIT OF MEASURE)	YEAR SAMPLED	AMOUNT DETECTED	RANGE LOW-HIGH
Bromochloromethane (ppm)	2006	0.0120	NA
Bromoform (ppm)	2006	0.0030	NA
Chlorodibromomethane (ppm)	2006	0.0075	NA
Chloroform (ppm)	2006	0.0075	NA
Sulfate (ppm)	2006	44.3	NA

Footnotes:

¹ The MCL for beta particles is 4 mrem/year. The U.S. EPA considers 50 pCi/L to be the level of concern for beta particles.

² Depending on the TOC in our source water, the system must remove a certain percentage of TOC or must achieve alternative compliance criteria. If we do not achieve that percentage of removal, there is an alternative percentage of removal. If we fail to meet the alternative percentage of removal, we are in violation of a treatment technique.

³ Turbidity is a measure of the cloudiness of the water. We monitor it because it is a good indicator of the effectiveness of our filtration system. The turbidity rule requires that 95% or more of the monthly samples must be less than or equal to 0.3 NTU.

⁴ Lead was not detected at the 90th percentile.

Table Definitions

AL (Action Level): The concentration of a contaminant, which, if exceeded, triggers treatment or other requirements, which a water system must follow.

MCL (Maximum Contaminant Level): The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLG's as feasible using the best available treatment technology.

MCLG (Maximum Contaminant Level Goal): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLG's allow for a margin of safety.

MRDL (Maximum Residual Disinfectant Level): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

MRDLG (Maximum Residual Disinfectant Level Goal): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLG's do not reflect the benefits of the use of disinfectants to control microbial contaminants.

NA: Not applicable

NTU (Nephelometric Turbidity Units): Measurement of the clarity, or turbidity, of water. Turbidity in excess of 5 NTU is just noticeable to the average person.

pCi/L (picocuries per liter): A measure of radioactivity.

ppb (parts per billion): One part substance per billion parts water (or micrograms per liter).

ppm (parts per million): One part substance per million parts water (or milligrams per liter).

TT (Treatment Technique): A required process intended to reduce the level of a contaminant in drinking water.

Cryptosporidium in Source Water

Cryptosporidium is a microbial parasite found in surface water throughout the United States. Although filtration removes *Cryptosporidium*, the most commonly used filtration methods cannot guarantee 100% removal. *Cryptosporidium* has been detected in the source water supplying the plant at very low concentrations. Although the water plant provides filtration and has not detected *Cryptosporidium* in the drinking water, we are required to notify you of the potential associated risks. Current test methods do not allow us to determine if the organisms are dead or if they are capable of causing disease. Symptoms of infection include nausea, diarrhea, and abdominal cramps. Most healthy individuals can overcome the disease within a few weeks; however, immunocompromised people are at greater risk of developing a life-threatening illness. We encourage immunocompromised individuals to consult their doctors regarding appropriate precautions to take to avoid infection. *Cryptosporidium* must be ingested to cause disease, and it may be spread through means other than drinking water.



City of Sanford Public Access Channel

Please view the City of Sanford's Public Access Channel on Charter Cablevision Channel 11 for coverage of Council meetings, sewer and water construction activities, street closings, community announcements, and other information relevant to City activities.