



Notes:

1. Refer to detail SD-W-001 for meter details.
2. Mueller or Ford brass valves, yoke fittings, and stops shall be provided.
3. Up to 8 meters per gang meter assembly are allowed.



Gang Meter

City of Sanford Engineering Dept - P.O. Box 3729 - Sanford, NC 27331

Dwg. No. SD-W-012

Date: 06/30/2020

Scale: Not To Scale

Drawn By: Staff